

VOF INSTALLATION INSTRUCTIONS:

- VOF must be installed vertically in the waste holding tank breather pipe.
- Vertical or near-vertical installation is required.
- Rubber sleeves and clamps may be used to install the filter in line.
(Note: There is no pressure buildup through the VOF.)
- Install VOF with arrows in line with outward air flow.
- If possible install so that periodic maintenance can be performed. This would consist of removing the top plate so the VOF load can be replaced.
- This maintenance is recommended every 18 months.

VENT ODOR FILTER LOAD REPLACEMENT


Instructions to replace the VOF Vent Odor Filter load.

CAUTION: USE PROPER CARE DURING THIS PROCEDURE WHEN HANDLING A USED VOF LOAD. USE OF RUBBER GLOVES AND DUST MASK IS RECOMENDED.

1. Remove the VOF housing from the vent line.
2. Remove the four 1/4" stainless steel bolts holding the cover and note the number engraved in the lid and side of the chamber used for alignment.
3. Remove the existing VOF load by grabbing the used bag and lifting it out of the cylinder. Place it in a plastic garbage bag before disposing. Leave the plastic discs inside the VOF chamber as they are there to allow better circulation of air and to prevent the carbon from becoming damp.
4. Place the new VOF load inside the VOF chamber and replace the cover using a small amount of silicone sealer between the side of the chamber and the cover. Re-align the numbers and fasten cover with previously removed 1/4" Bolts.
5. After the VOF chamber is assembled, reinstall in the vent line.
6. **WHEN TO CHANGE VOF LOAD:**
When odors permeate from your vent stack, which may be 6 to 18 months depending upon the amount of effluent.

CONFIDENTIAL STATEMENT: THIS DRAWING AND DESIGN IS THE PROPERTY OF MATRIX DESALINATION, INC. AND IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM. WITHOUT THE WRITTEN PERMISSION OF MATRIX DESALINATION, INC. ALL RIGHTS ARE RESERVED.

MATRIX DESALINATION, INC.
3255 SW 11TH AVENUE
FORT LAUDERDALE, FL., 33315



VENT ODOR FILTER
V.O.F. 6X12, 2" I/O
WELDED ALUMINUM BODY

DESCRIPTION	
SCALE	
DATE	11/23/2004
APP'D BY	
CHECK BY	
DRAWN BY	GWILLARD
TITLE	VOF SMALL 2IN
DRAWING #	07009
SHEET OF	1
REV#	